

LIGHTING SCHEDULE

PROJECT	EFOOD _RUBY 3
STAGE	DETAIL DESIGN
DATE	20/03/2023
REVISION DATE	23/06/2023

LOCATION	LUMINAIRE TAG	DESCRIPTION	IP Req.	POWER(W)	DRIVER*	V	CONTROL	CCT (K)	CRI	OPTICS	LUM COLOUR	ACCESSORIES
bathrooms, kitchen	ST.b	LED STRIP + ALU profile + Difusser. Cove lighting	IP65	10-15W/m	remote	24	DALI	3000	90	diffused	n/a	OPAL DIFF/ ALU PRO.
general spotlights, bathroom, kitchen	CRT.a	Ceiling Recessed Trimless Fixed Led downlight		6W	remote	700mA	DALI	3000	90	32	BLACK	
bathrooms	CRT.c	Ceiling Recessed Trimless Fixed Led downlight		5-7W	included	220-240	MAINS DIMMABLE	3000	90	36	BLACK	
meeting rooms	PF.a3	Linear pendant fixture direct / indirect L190cm - UGR 19 5640lm/m		max 40W/m	included	220	DALI x 2 (direct + indirect)	3000	90	diffused	WHITE	

BU1	BACKUP power feed - Mains Dimmable
BU2	BACKUP power feed - DALI remote driver
BU3	BACKUP power feed - DALI local driver
	DECORATIVE LIGHTING

PLEASE CHECK WITH LATEST MANUFACTURER'S INSTALLATION INSTRUCTIONS BEFORE PROCEEDING

*DRIVER NOTES:

Remote: Driver to be placed at a distance within limits
Local : Driver to be placed next to the luminaire through ceiling cut off
Included: Driver included in fixture

IMPORTANT NOTES

NOTE 1: PROVISION FOR DRAINAGE FOR ALL IN GROUND EXTERIOR FIXTURES
NOTE 2: ALL DIMABLE DRIVERS SHOULD HAVE LOW DIMMING / DIM TO DARK CAPABILITY WITHOUT FLICKERING
NOTE 3: THE LIGHTING CONSULTANT SHOULD DIRECT THE FOCUSING OF INSTALLED LIGHTING SCHEME WHERE APPLICABLE ON SITE
NOTE 4: THE LIGHTING CONSULTANT SHOULD DIRECT THE PROGRAMMING OF INSTALLED CONTROL EQUIPEMENT WHERE APPLICABLE ON SITE
NOTE 5: REVIEW AND CHECKING OF PROPOSED SUBSTITUTE LUMINAIRES, AS SELECTED BY OTHERS, SHOULD BE CHECKED BY LIGHTING CONSULTANT FOR COMPLIANCE WITH THE SPECIFICATION
NOTE 6: ALL DRIVERS AND LUMINAIRES SHOULD BE CHECKED BY KNX / INSTABUS CONSULTANT FOR COMPATIBILITY WITH SPECIFIED LIGHTING CONTROLS
NOTE 7: ALL LUMINAIRES AND DRIVERS SHOULD HAVE THE NECESSARY INSTALLATION ACCESSORIES